

2025 | ANNUAL CONSUMER CONFIDENCE REPORT (CCR)

WATER QUALITY REPORT

WSID #2370000

YOUR WATER MEETS ALL FEDERAL AND STATE REGULATIONS FOR WATER QUALITY

THE EATONTON-PUTNAM WATER & SEWER AUTHORITY (EPWSA) IS PLEASED TO PRESENT THIS WATER QUALITY ANNUAL REPORT TO THE RESIDENTS OF THE CITY OF EATONTON AND PUTNAM COUNTY.

EPWSA is committed to delivering an exceptional level of service while providing you with reliable, safe and high quality utility services. We are able to meet your needs and exceed your expectations only through the remarkable efforts of a dedicated team of employees and our passionate pursuit of excellence.



THIS ANNUAL WATER QUALITY REPORT EXPLAINS WHERE YOUR DRINKING WATER COMES FROM, HOW IT IS TREATED AND TESTED TO ENSURE IT IS SAFE FOR YOU AND YOUR FAMILY, AND THE ONGOING STEPS WE TAKE TO PROTECT OUR VALUABLE NATURAL RESOURCES.

Your Water Quality Report provides information on water quality and the results of hundreds of tests performed every day of the year from sampling locations from source to tap. These daily tests ensure your water is safe, clean and healthy.If you have any questions about this report, please contact Brice Doolittle or Freddie Wiggins with ESG Operations at (706) 485-5252. To stay informed about your water utility, you are also welcome to attend any of our regularly scheduled Board meetings. The meeting dates are posted on our website at www.epwsa.com and are held at 4:30 p.m. at the main office located at 663 Godfrey Road, Eatonton, GA 31024. Your participation and comments are welcome!

YOUR WATER IS SAFE TO DRINK!

Eatonton-Putnam Water and Sewer Authority
663 Godfrey Road
Eatonton, Georgia 31024
(706) 485-5252
www.epwsa.com

Water testing performed from January 1, 2025 through December 31, 2025

Esta informe contiene informacion muy importante sobre la calidad de su agua de beber. Si no entiende bien por favor busce alguien que le tradusca la informacion

EPWSA BOARD OF DIRECTORS

Commissioner Bill Sharp
2025 Chairman
Mayor John Reid
Vice-Chairman
Judd Doster, *Member*
Jay Gregory, *Member*
Mike Rowland, *Member*



WHERE YOUR DRINKING WATER COMES FROM

EPWSA purchases all its water from the Sinclair Water Authority (SWA). Water from Lake Sinclair is pumped to SWA where it undergoes a coagulation/sedimentation process to remove the bulk of contaminants from the water. Following this step in the treatment process is ultrafiltration through membranes which provide a physical barrier removing contaminants down to 0.02 microns. The final step in the process is disinfection which keeps the water safe all the way from treatment to the customer's tap. SWA can produce up to 6 million gallons of safe and clean drinking water every day.

The U.S. Environmental Protection Agency (EPA) and the Georgia Environmental Protection Division (EPD) have implemented strategies for assessing potential contamination and promoting protection of Georgia's drinking water sources. These strategies are referred to as Source Water Assessments and they identify potential sources of contamination as well as a susceptibility analysis for each identified contamination source. The Sinclair Water Authority retains a copy of the Source Water Assessment plan, showing that the water is within acceptable limits and can be used as a source of public water supply. Please contact Sinclair Water Authority for more information or to review of copy of the source water assessment.



CONTAMINANTS

EPWSA routinely monitors for contaminants in your drinking water according to federal and state laws. The Table of Detected Contaminants on page 3 shows the results of our monitoring for the period of January 1, 2025 through December 31, 2025.

The sources of drinking water (both tap and bottled water) includes rivers, lakes, ponds, streams, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and it can pick up substances resulting from the presence of animals or from human activity.

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).**

Contaminants that may be present in source water before treatment include the following:

- *Microbial Contaminants* such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife
- *Inorganic Contaminants* such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharge, oil and gas production, mining, or farming
- *Pesticides and Herbicides* which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses
- *Organic Chemical Contaminants* including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems
- *Radioactive Contaminants* which can be naturally occurring or be the result of oil and gas production and mining activities

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

WATER QUALITY DATA

2025 TABLE OF DETECTED CONTAMINANTS

CONTAMINANT	MCL	MCLG	RESULTS		DATE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
			AVERAGE	RANGE			
Fluoride (ppm)	4	4	0.77	0.11-1.38	2025	No	Water additive which promotes strong teeth
Chlorine (ppm)	4	4	1.07	0.20-1.70	2025	No	Water additive used to control microbes
Total Coliform Bacteria	0 positive monthly sample	0	0 positive out of 120 samples	0-0	2025	No	Naturally present in the environment
Trihalomethanes (ppb)	80	N/A	35.08	16.00-69.00	2025	No	By-product of drinking water chlorination
Haloacetic Acids (ppb)	60	N/A	24.59	7.70-49.80	2025	No	By-product of drinking water chlorination
Lead (ppb)	15	15	0.001	0.0002-0.001	2025	No	Corrosion of household plumbing systems
Copper (ppb)	1.3	1.3	0.05	0.0020-0.146	2025	No	Corrosion of household plumbing systems

All results in parts per million (ppm) unless noted otherwise.

TERMS AND ABBREVIATIONS

In the table above, you will find terms and abbreviations you may not be familiar with. To help you better understand these terms, we have provided the following definitions:

- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Nephelometric Turbidity Unit (NTU)** – A measurement used to indicate the clarity of water.
- **Non-Detects (ND)** – Laboratory analysis indicates that the constituent is not present
- **Parts per billion (ppb)** – A measure of the concentration by weight of a substance. This is the same as one penny in ten million dollars
- **Parts per million (ppm)** – A measure of the concentration by weight of a substance. This is the same as one penny in ten thousand dollars.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.



MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

YOUR WATER IS SAFE TO DRINK

As you can see in our Water Quality Table at left, the EPWSA had no violations in 2025.

Not only do we monitor our water according to state and federal regulations, we also run our own water quality monitoring on a continual basis during plant operations to ensure that we are producing safe and reliable drinking water for our customers.



YOUR HEALTH IS OUR HIGHEST PRIORITY



At EPWSA the safety and quality of the water we supply you is of great importance to us. Our results show that we have been very successful in our efforts to minimize the tendency for lead to enter the water. Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Eatonton-Putnam Water and Sewer Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by **identifying and removing** lead materials within your home plumbing and taking steps to reduce your family's risk.

Using a filter, certified by an American National Standards Institute accredited certifier, to reduce lead is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes.

If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact EPWSA at 706-485-5252. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at https://www.epa.gov/safewater/lead.

EPWSA is required to monitor and collect samples for lead once every three years; our last sampling date was September 2022. We select a representative sample of homes in our service area to participate in the study. Customers in these homes are provided sample bottles and asked to collect the first draw of water in the morning. We retrieve the sample bottles and test them for lead and copper levels. The US EPA has established an "action level" of 15 ug/L for lead and 1.3 mg/L for copper. Our system is well within compliance of these limits (see "Table of Detected Contaminants" in this report).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

WE ARE HERE TO HELP!

If you have questions, concerns or need additional information regarding the safety and quality of your water, please contact Brice Doolittle or Freddie Wiggins at 706-485-5252. Additional copies of this Water Quality report are available at your public library or on our website at www.epwsa.com.

THIS ANNUAL REPORT
WAS PREPARED BY INFRAMARK, LLC

Proudly serving the Eatonton-Putnam Water & Sewer Authority since 2020.

INFRAMARK

www.inframark.com